

Northeast Georgia Source Water Assessment Susceptibility Analysis

CITY OF MONTICELLO - LOWRY BRANCH

<i>Potential Source Description</i>	Release Potential						Risk Potential	
	Distance from Water	Ease of Travel	Volume of Release	Duration of Release	Supplemental Guidance	Toxicity	Distance from Intake	
	(Comments)			(Comments)		(Comments)		
IMZ								
ZZ-125	Road Crossing		MEDIUM			MEDIUM		
Secondary road	H	H	M	M	L	M	H	
				could have a one-time catastrophic event	less than 50 stream crossings	chronic, chemicals from tanker trucks		

*Note: Distance from Water - H (within 500 ft), L (further than 500 ft); Ease - H (hilly, overland flow very likely), M (moderate topography, overland flow likely), L (flat, overland flow not likely)
 Distance from Intake - H (within 7 miles upstream), M (between 7 and 15 miles), L (greater than 15 miles)*